



## Assumption Change Control Sheet

<b>Test</b>	1a, - 1f, Space heating Tests
<b>Assumption</b>	12. Permitted variation in secondary return temperature, $t_{21}$ .

Change Originator	MC
<b>Change Request No.</b>	010
Date of Request	17/12/2019
Proposed Change to Assumption?	<b>No</b>

### Proposed Approach

Retain permitted variation of  $\pm 0.5^{\circ}\text{C}$

### Rationale (underlying basis for assumption)

$0.5^{\circ}\text{C}$  is the balance between a practically achievable tolerance on the test rig and the accuracy / consistency of the resulting return temperature measurement, as discussed with Test Houses.

### Impact of Change (e.g. implications for test rig)

N/A

### CHANGE EVALUATION

Date Evaluated	17/12/2019
Additional Information Required?	N
Modification to Proposed Approach?	N
Details	
Signed-off	Y