



Assumption Change Control Sheet

Test	1a, - 1f, Space heating Tests
Assumption	13. Permitted variation in space heating output.

Change Originator	Martin Crane
Change Request No.	011
Date of Request	17/12/2019
Proposed Change to Assumption?	No

Proposed Approach

Retain permitted variation of +/- 10% or 0.25kW (whichever is smallest)

Rationale (underlying basis for assumption)

This is the balance of practically achievable tolerances on the test rig and the accuracy / consistency of the resulting return temperature measurement, as discussed with Test Houses. The tests undertaken, to date, show there is not a large variation in return temperatures at different heat outputs so the accuracy of the heat outputs is not too important.

Impact of Change (e.g. implications for test rig)

N/A

CHANGE EVALUATION

Date Evaluated	17/12/2019
Additional Information Required?	N
Modification to Proposed Approach?	N
Details	
Signed-off	Y