



Change Note		CN-046
Change to: Technical Assumption 47		
Description: HIU orientation		
References: Test regime paragraph 2.6, all Tests		
Change originator: FV		Date of request: 30/06/21
Rev: 01	Date authored: 21/09/21	Proposed change to assumption: N

1. Proposed Approach

HIU to be oriented vertically.

Criteria as previously.

2. Rationale (underlying basis for the change)

To represent orientation of HIUs when installed.

3. Impact of change (e.g. implications for test rig)

N/A

Evaluation of change			
Date evaluated: 30/06/21	Those present: GJ, RH, SC, MO & FV	Additional info required?: N	Modification to proposed approach?: N
Details: Confirmation of HIU orientation			
Signed off: Yes			