

Change Note		CN-044
Change to: Technical Assumption 43		
Description: Enabling of keep warm		
References: Test regime paragraph 4.33, Tests 4a & 4b		
Change originator: FV		Date of request: 30/06/21
Rev: 01	Date authored: 21/09/21	Proposed change to assumption: N

1. Proposed Approach

For HIUs that can enable/disable their keep warm function:

For HIUs undergoing “keepwarm on” modules, keepwarm must be enabled at all times and operation/set up detailed.

For HIUs undergoing “keepwarm off” modules, keepwarm must be disabled and operation/set up detailed.

2. Rationale (underlying basis for the change)

To provide consistency and full clarity on keep warm set up and operation.

3. Impact of change (e.g. implications for test rig)

Keep warm description and set up will need to be detailed in the report.

Evaluation of change			
Date evaluated: 30/06/21	Those present: GJ, RH, SC, MO & FV	Additional info required?: N	Modification to proposed approach?: Y
Details: Confirmation of HIU keep warm set up.			
Signed off: Yes			