

Change Note		CN-050
Change to: Technical Assumption 59		
Description: DH source temperature tolerance.		
References: Test regime paragraphs 2.19, Tests 4a & 4b		
Change originator: FV		Date of request: 30/06/21
Rev: 01	Date authored: 21/09/21	Proposed change to assumption: N

1. Proposed Approach

District heating source temperature, t10, variation to be ± 0.5 °C.

Criteria as previously.

2. Rationale (underlying basis for the change)

To ensure that district heating source temperature does not impact HIU performance during keep warm test.

3. Impact of change (e.g. implications for test rig)

N/A

Evaluation of change			
Date evaluated: 30/06/21	Those present: GJ, RH, SC, MO & FV	Additional info required?: N	Modification to proposed approach?: N
Details: Confirmation of district heating source temperature variation			
Signed off: Yes			