



Assumption Change Control Sheet

Test	2a, 2b Dynamic DHW Tests
Assumption	21. Dynamic test including both on/ off and change of flow.

Change Originator	Martin Crane
Change Request No.	013
Date of Request	17/12/2019
Proposed Change to Assumption?	No

Proposed Approach

Retain current dynamic test profile that include both on/off and change of DHW flowrate.

Rationale (underlying basis for assumption)

Many HIUs seem to respond differently when changing from 0.13 to 0.06 l/sec and back again as opposed to on/off. Important consideration for resident comfort and safety.

Impact of Change (e.g. implications for test rig)

N/A

CHANGE EVALUATION

Date Evaluated	17/12/2019
Additional Information Required?	N
Modification to Proposed Approach?	N
Details	
Signed-off	Y