



Assumption Change Control Sheet

Test	1a, - 1f, Space heating Tests
Assumption	11. Permitted variation in secondary flow temperature, t_{22} .

Change Originator	Martin Crane
Change Request No.	009
Date of Request	17/12/2019
Proposed Change to Assumption?	No

Proposed Approach

Retain permitted variation of $\pm 0.5^{\circ}\text{C}$

Rationale (underlying basis for assumption)

0.5°C is the balance between a practically achievable tolerance on the test rig and the accuracy / consistency of the resulting return temperature measurement, as discussed with Test Houses.

Impact of Change (e.g. implications for test rig)

N/A

CHANGE EVALUATION

Date Evaluated	17/12/2019
Additional Information Required?	N
Modification to Proposed Approach?	N
Details	
Signed-off	Y