

| | | |
|---|-----------------------------------|---|
| Change Note | | CN-056 |
| Change to: Technical Assumptions 75, 76 & 77 | | |
| Description: HIU Guides | | |
| References: Test regime paragraph 3.7, Submitted documentation | | |
| Change originator: FV | | Date of request: 30/06/21 |
| Rev: 01 | Date authored: 12/11/21 | Proposed change to assumption: N |

1. Proposed Approach

The following HIU guides must be submitted:

- Installation guide.
- Commissioning guide – Note: this should include sufficiently clear instructions that the test house is able to commission the HIU in preparation for the test procedure.
- Operation guide with a function and operation description and care instructions, as suited to the intended user category.

Criteria as previously.

2. Rationale (underlying basis for the change)

Ensures that HIU manufacturers recommended instructions are utilised by the test house.

3. Impact of change (e.g. implications for test rig)

N/A

| | | | |
|---|--|---|--|
| Evaluation of change | | | |
| Date evaluated: 30/06/21 | Those present: GJ, RH, SC, MO & FV | Additional info required?: N | Modification to proposed approach?: N |
| Details: Confirmation HIU guides to be submitted | | | |
| Signed off: Yes | | | |

