

Change Note		CN-049
Change to: Technical Assumption 57		
Description: Primary flow temperature variation, during stable conditions.		
References: Test regime paragraphs 2.15, 4.8 & 4.18; all Tests except 4a & 4b		
Change originator: FV		Date of request: 30/06/21
Rev: 01	Date authored: 21/09/21	Proposed change to assumption: N

1. Proposed Approach

Primary flow temperature, t11, variation in stable conditions to be ± 0.5 °C.

Criteria as previously.

2. Rationale (underlying basis for the change)

To ensure that primary flow temperature does not impact HIU performance.

3. Impact of change (e.g. implications for test rig)

N/A

Evaluation of change			
Date evaluated: 30/06/21	Those present: GJ, RH, SC, MO & FV	Additional info required?: N	Modification to proposed approach?: N
Details: Confirmation of primary flow temperature variation			
Signed off: Yes			