



Assumption Change Control Sheet

Test	1a, 1b, 1c High temperature space heating Test
Assumption	10. Space heating return temperature

Change Originator	Martin Crane
Change Request No.	008
Date of Request	17/12/2019
Proposed Change to Assumption?	No

Proposed Approach

Retain return temperature of 40°C

Rationale (underlying basis for assumption)

The CIBSE CP1 (2020) maximum temperature for space heating from radiators and fan coil is 40°C. Ref Objective 3.4

Impact of Change (e.g. implications for test rig)

N/A

CHANGE EVALUATION

Date Evaluated	17/12/2019
Additional Information Required?	N
Modification to Proposed Approach?	N
Details	
Signed-off	Y