

Change Note		CN-043
Change to: Technical Assumption 42		
Description: Use of electronic devices		
References: Test regime paragraph 3.12		
Change originator: FV		Date of request: 30/06/21
Rev: 01	Date authored: 21/09/21	Proposed change to assumption: Y

1. Proposed Approach

No electronic devices should be attached to the HIU during testing other than with prior agreement with the test house in order to change settings. This includes any device used for monitoring purposes only or any device used for remote connection to the HIU.

Any electronic device utilised must be included in the list of HIU components.

2. Rationale (underlying basis for the change)

To ensure full clarity on exact HIU set up and configuration during test.

3. Impact of change (e.g. implications for test rig)

HIU component list to be updated.

Evaluation of change			
Date evaluated: 30/06/21	Those present: GJ, RH, SC, MO & FV	Additional info required?: N	Modification to proposed approach?: N
Details: Confirmation of usage of electronic devices.			
Signed off: Yes			