



## Assumption Change Control Sheet

<b>Test</b>	All tests
<b>Assumption</b>	Flow restrictor to replicate heat meter if heat meter not fitted.

Change Originator	Martin Crane
<b>Change Request No.</b>	033
Date of Request	23/07/2020
Proposed Change to Assumption?	N

### Proposed Approach

If no heat meter fitted, a flow restrictor to replicate heat meter of 25kPa at 1m<sup>3</sup>/hr is to be used.

### Rationale (underlying basis for assumption)

Aims to simulate the pressure drop that would've occurred across the heat meter.

### Impact of Change (e.g. implications for test rig)

### CHANGE EVALUATION

Date Evaluated	23/07/2020
Additional Information Required?	N
Modification to Proposed Approach?	N
Details	
Signed-off	Y