

Change Note		CN-069
Change to: Technical Assumption 53		
Description: Space heating system pressure		
References: Test regime paragraph 2.12, all Tests		
Change originator: FV		Date of request: 30/06/21
Rev: 01	Date authored: 21/09/21	Proposed change to assumption: N

1. Proposed Approach

Space heating system pressure to be 1.5 bar \pm 5 %.

Criteria as previously.

2. Rationale (underlying basis for the change)

Representative pressure of space heating systems.

3. Impact of change (e.g. implications for test rig)

N/A

Evaluation of change			
Date evaluated: 30/06/21	Those present: GJ, RH, SC, MO & FV	Additional info required?: N	Modification to proposed approach?: N
Details: Confirmation of space heating system pressure			
Signed off: Yes			