

Change Note		CN-059
Change to: Technical Assumption 81		
Description: Time to Achieve Target DHW Flow Rates		
References: Test regime paragraph 3.7, Tests 2-5		
Change originator: FV		Date of request: 30/06/21
Rev: 01	Date authored: 12/11/21	Proposed change to assumption: N

1. Proposed Approach

The time to achieve 95% of the target DHW flow rates shall not exceed 5 seconds from the onset of the flow change.

Criteria as previously.

2. Rationale (underlying basis for the change)

To ensure consistency between tests and test houses during DHW tests.

3. Impact of change (e.g. implications for test rig)

N/A

Evaluation of change			
Date evaluated: 30/06/21	Those present: GJ, RH, SC, MO & FV	Additional info required?: N	Modification to proposed approach?: N
Details: Confirmation on time allowance to reach required DHW flow rates.			
Signed off: Yes			