



## Assumption Change Control Sheet

<b>Test</b>	3a, 3b Low flow DHW Tests
<b>Assumption</b>	23. Duration of low flow test

Change Originator	Martin Crane
<b>Change Request No.</b>	014
Date of Request	17/12/2019
Proposed Change to Assumption?	<b>No</b>

### Proposed Approach

Retain current 180 second test duration.

### Rationale (underlying basis for assumption)

Based on test undertaken to date HIU tend to have stabilised before 180 seconds. Hence 180 seconds is considered sufficient time to show any untoward behaviour.

### Impact of Change (e.g. implications for test rig)

N/A

### CHANGE EVALUATION

Date Evaluated	17/12/2019
Additional Information Required?	N
Modification to Proposed Approach?	N
Details	
Signed-off	Y