

Appendix 3. VVART calculations

Low temperature VVART calculations with keep warm function active

Low temperature VVART Calculation for Uponor with keep warm active

Test carried out by RISE in November 2019

Manufacturer: Uponor; Model: Combi Port PRO XU; Serial number: D-10-0244263; Year of manufacture: 2019

VVART calculation prepared by Henrik Persson of RISE on 06 December 2019

	VVART	Volume
DHW	20,2	34,19
Standby	48,3	128,68
Space Heating	35,2	56,16

Period	VVART	% Time
No Heating	42,4	93%
Heating	36,4	7%
Overall	42	

	DHW Draw test results			Post DHW Draw (60 seconds)	
	Power (W)	Primary flow (m3/hr)	Return Temp(°C)	Primary flow (m3/hr)	Avg Return Temp(°C)
Low	10283	0,227	20,5	0,020	20,4
Medium	16110	0,349	20,1	0,018	19,9
High	21202	0,453	19,8	0,022	19,6

DHW Draw Volumes per annum		
kWh	Hours	Volume pa (m3)
729	70,89	16,093
297	18,44	6,434
444	20,94	9,486

Post DHW Draw Volumes per annum		
Events	Average duration (secs)	Volume pa (m3)
10000	30	1,667
660	75	0,248
300	145	0,266

Standby	Standby test results	
	Primary flow (m3/hr)	Return Temp(°C)
	0,016	48,3

Standby Volumes pa	
Hours	Volume pa (m3)
8 043	128,68

	Space Heating test results		
	Power (W)	Primary flow (m3/hr)	Return Temp(°C)
1kWp	1025	0,066	34,9
2kWp	2144	0,080	35,2
4kWp	3916	0,142	35,2

Space Heating Volumes pa		
kWh pa	Hours	Volume pa (m3)
98	95,61	6,310
787	367,07	29,366
565	144,28	20,488