

## Appendix 3. VWARD calculations

### High temperature VWARD calculations with keep warm function active

High temperature VWARD Calculation for Uponor with keep warm active

Test carried out by RISE in November 2019

Manufacturer: Uponor; Model: Combi Port PRO XU; Serial number: D-10\_0244263; Year of manufacture: 2019

VWARD calculation prepared by Henrik Persson of RISE on 06 December 2019

|               | VWARD | Volume |
|---------------|-------|--------|
| DHW           | 19,4  | 26,69  |
| Standby       | 45,9  | 88,43  |
| Space Heating | 41,0  | 16,54  |

| Period         | VWARD     | % Time |
|----------------|-----------|--------|
| No Heating     | 39,7      | 93%    |
| Heating        | 40,6      | 7%     |
| <b>Overall</b> | <b>40</b> |        |

|        | DHW Draw test results |                      |                 | Post DHW Draw (60seconds) |                     |  |
|--------|-----------------------|----------------------|-----------------|---------------------------|---------------------|--|
|        | Power (W)             | Primary flow (m3/hr) | Return Temp(°C) | Primary flow (m3/hr)      | Avg Return Temp(°C) |  |
| Low    | 11394                 | 0,199                | 19,5            | 0,009                     | 19,5                |  |
| Medium | 17600                 | 0,306                | 19,3            | 0,013                     | 19,1                |  |
| High   | 23408                 | 0,402                | 19,2            | 0,020                     | 19,1                |  |

| DHW Draw Volumes per annum |       |                |
|----------------------------|-------|----------------|
| kWh                        | Hours | Volume pa (m3) |
| 729                        | 63,98 | 12,732         |
| 297                        | 16,88 | 5,164          |
| 444                        | 18,97 | 7,625          |

| Post DHW Draw Volumes per annum |                         |                |
|---------------------------------|-------------------------|----------------|
| Events                          | Average duration (secs) | Volume pa (m3) |
| 10000                           | 30                      | 0,750          |
| 660                             | 75                      | 0,179          |
| 300                             | 145                     | 0,242          |

| Standby | Standby test results |                 |
|---------|----------------------|-----------------|
|         | Primary flow (m3/hr) | Return Temp(°C) |
|         | 0,011                | 45,9            |

| Standby Volumes pa |                |
|--------------------|----------------|
| Hours              | Volume pa (m3) |
| 8 039              | 88,43          |

|      | Space Heating test results |                      |                 |
|------|----------------------------|----------------------|-----------------|
|      | Power (W)                  | Primary flow (m3/hr) | Return Temp(°C) |
| 1kWp | 1026                       | 0,043                | 40,3            |
| 2kWp | 2058                       | 0,019                | 40,9            |
| 4kWp | 3938                       | 0,036                | 41,6            |

| Space Heating Volumes pa |        |                |
|--------------------------|--------|----------------|
| kWh pa                   | Hours  | Volume pa (m3) |
| 98                       | 95,52  | 4,107          |
| 787                      | 382,41 | 7,266          |
| 565                      | 143,47 | 5,165          |