



High Temperature VVART Calculation for Heatlink HL3000-E HIU

Primary flow temperature: 70°C; DHW set point: 55°C; Space heating temperatures: 60°C/40°C

Test carried out by Enertek International for HIGH Temperature BESA Tests

Manufacturer: Taconova Group; Model: HL3000-E; Serial number: 696-00003;

VVART calculation prepared by Ian Williamson of Enertek International on 26 March 2020

Table 7.2 - key metrics of High Temperature Package

	VVART(°C)	Volume (m3)
DHW	16	23.1
Standby	39	13.0
Space Heating	42	47.6

VVART with Keep warm active		
Period	VVART(°C)	% Time
No Heating	25	93%
Heating	41	7%
Overall	26	

	DHW Draw test results			Post DHW Draw (60 seconds)	
	Power (W)	Primary flow (ls)	VVART (°C)	Primary flow (m ³ /hr)	VVART (°C)
Low	10013	0.042	16	0.000	15
Medium	18220	0.083	17	0.000	16
High	23265	0.103	17	0.000	17

DHW Draw Volumes pa		
kWh pa	Hours	Volume pa (m ³)
729	73.00	11.10
297	16.00	4.90
444	19.00	7.10

Post DWH Draw Volumes pa		
Events pa	Average duration (secs)	Volume pa (m ³)
10000	30	-
660	75	-
300	145	-

Standby	Standby test results	
	Primary flow (Ls ⁻¹)	VVART (°C)
	0.000500	39

Standby Volumes pa	
Hours	Volume pa (m ³)
8,008	13.00

	Space Heating test results		
	Power (W)	Primary flow (Ls ⁻¹)	VVART (°C)
1kWp	959	0.010	42
2kWp	1945	0.018	42
4kWp	4066	0.034	42

Space Heating Volumes pa		
kWh pa	Hours	Volume pa (m ³)
98	102.00	3.70
787	405.00	26.20
565	143.00	17.70